

| Date       | Auxiliary Program Center (APC- f.k.a., Kindergarten Module), Location | Sample ID | Copper     | Lead         |
|------------|---|-----------|------------|--------------|
| 9/28/2023  | APC, SF in kitchen (lead/copper only)                                 | APC-17    | 0.3        | 0.0011       |
| 12/12/2024 | APC, SF in kitchen (lead/copper only)                                 | APC-18    | 0.21       | <0.0010      |
| 12/12/2024 | APC, WBFS in Kitchen (lead/copper only)                               | APC-19    | 0.055      | <0.0010      |
|            | <b>Action Level (EPA/ MDEQ)</b>                                       |           | <b>1.3</b> | <b>0.015</b> |

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level