

Date	Computer Information Science (CIS) Building, Location	Sample ID	Copper	Lead
10/3/2023	CIS, DF by room 105 (lead/copper only)	CIS-40	0.45	<0.0010
10/3/2023	CIS, DF by room 205 (lead/copper only)	CIS-41	0.44	0.0013
10/3/2023	CIS, SF in room 225 (lead/copper only)	CIS-42	0.13	<0.0010
12/12/2024	CIS, DF by room 105 (lead/copper only)	CIS-43	0.48	<0.0010
12/12/2024	CIS, DF by room 205 (lead/copper only)	CIS-44	0.39	<0.0010
12/12/2024	CIS, SF in room 225 (lead/copper only)	CIS-45	0.16	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level