

Date	Campus Support Services (CSS) Building, Location	Sample ID	Copper	Lead
10/3/2023	CSS, SF by Fac. Ops Maintenance shop/vending area (lead/copper only)	CSS-20	0.22	<0.0010
10/3/2023	CSS, DF in hallway, adjacent to Room 1340- DPS Suite (lead/copper only)	CSS-21	0.3	<0.0010
10/3/2023	CSS, DF in front lobby (lead/copper only)	CSS-22	0.28	<0.0010
10/3/2023	CSS, SF near Room 1330- Inside DPS Suite (lead/copper only)	CSS-23	0.11	<0.0010
12/13/2024	CSS, SF by Fac. Ops Maintenance shop/vending area (lead/copper only)	CSS-24	0.19	<0.0010
12/13/2024	CSS, DF in hallway, adjacent to Room 1340- DPS Suite (lead/copper only)	CSS-25	0.27	<0.0010
12/13/2024	CSS, DF in front lobby (lead/copper only)	CSS-26	0.19	<0.0010
12/13/2024	CSS, KSF in Room 1205- Mail Room Kitchnette (lead/copper only)	CSS-27	0.12	<0.0010
	<b>Action Level (EPA/ MDEQ)</b>		<b>1.3</b>	<b>0.015</b>

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level