Date	Early Childhood Education Center (ECEC), Location	Sample ID	Copper	Lead
10/5/2023	ECEC, SF in room 159 (lead/copper only)	ECEC-89	0.088	<0.0010
10/5/2023	ECEC, SF in room 146 (lead/copper only) - Teacher Workroom	ECEC-90	0.37	<0.0010
10/5/2023	ECEC, KSF (stock faucet) room 144 (lead/ copper only)	ECEC-91	0.28	<0.0010
10/5/2023	ECEC, KF in room 307 (lead/copper only)	ECEC-92	0.099	<0.0010
10/5/2023	ECEC, SF in room 317 (lead/copper only)	ECEC-93	0.17	<0.0010
10/5/2023	ECEC, tall DF by rooms 317/319 (lead/ copper only)	ECEC-94	0.12	<0.0010
10/5/2023	ECEC, SF in room 319 (lead/copper only)	ECEC-95	0.1	<0.0010
10/5/2023	ECEC, SF in room 320 (lead/copper only)	ECEC-96	0.1	<0.0010
10/5/2023	ECEC, SF in room 334 (lead/copper only)	ECEC-97	0.067	<0.0010
10/5/2023	ECEC, KF in room 343 (lead/copper only	ECEC-98	0.085	<0.0010
12/18/2024	ECEC, SF in room 161 (lead/copper only)	ECEC-99	0.13	<0.0010
12/18/2024	ECEC, SF in room 146 (lead/copper only) - Teacher Workroom	ECEC-100	0.43	<0.0010
12/18/2024	ECEC, KSF (stock faucet) room 144 (lead/ copper only)	ECEC-101	0.27	<0.0010
12/18/2024	ECEC, SF in room 309 (lead/copper only)	ECEC-102	0.11	<0.0010
12/18/2024	ECEC, SF in room 311 (lead/copper only)	ECEC-103	0.059	<0.0010
12/18/2024	ECEC, Short DF by rooms 317/319 (lead/copper only)	ECEC-104	0.12	<0.0010
12/18/2024	ECEC, SF in room 319 (lead/copper only)	ECEC-105	0.15	<0.0010
12/18/2024	ECEC, SF in room 322, Art Studio (lead/copper only)	ECEC-106	0.41	<0.0010
12/18/2024	ECEC, SF in room 334 (lead/copper only)	ECEC-107	0.16	<0.0010
12/18/2024	ECEC, SF in room 343 (lead/copper only)	ECEC-108	0.061	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

KF = kitchen faucet

TF = toilet faucet

SF = sink faucet

DF = drinking fountain

DCF = diaper change room faucet

LRF = lactating room faucet

KSF = kitchen prep faucet

- Some kitchen sinks had PUR filters on their stem, but were not activated during sampling

 $^{\ ^{*}}$ - Any toilet room faucets sampled is mixed, cold with hot water

Date	Early Childhood Education Center (ECEC), Location	Sample ID	Copper	Lead
	All sink faucets and kitchen faucets were sampled while running cold water			
	Highlighted Orange = elevated above Action Level			