

Date	Engineering Lab Building (ELB), Location	Sample ID	Copper	Lead
10/5/2023	ELB, SF, North wing, Conference Room 1094 (lead /copper only)	ELB-38	0.54	<0.0010
10/5/2023	ELB, SF in room 1541 (lead/copper only)	ELB-39	0.97	<0.0010
10/5/2023	ELB, Tall DF, South wing, 1st floor, by elevator lobby	ELB-40	0.32	<0.0010
10/5/2023	ELB, Short DF by room 1055 (lead/copper only)	ELB-41	0.2	<0.0010
10/5/2023	ELB, WBFS, South wing, 2nd floor, by elevator lobby	ELB-42	0.34	<0.0010
10/5/2023	ELB, SF in room 2394 (lead/copper only)	ELB-43	0.68	<0.0010
10/5/2023	ELB, WBFS, North wing, 2nd floor, by restrooms	ELB-44	0.27	<0.0010
10/5/2023	ELB, Tall DF, South wing, 3rd floor, by elevator lobby	ELB-45	0.27	<0.0010
10/5/2023	ELB, SF by room 3047 (lead/copper only)	ELB-46	0.68	<0.0010
10/5/2023	ELB, Tall DF by room 3061 (lead/copper only)	ELB-47	0.14	<0.0010
12/17/2024	ELB, SF, North Wing, Conference Room 1094 (lead /copper only)	ELB-48	0.71	<0.0010
12/17/2024	ELB, SF in room 1541 (lead/copper only)	ELB-49	0.98	<0.0010
12/17/2024	ELB, Tall DF, North Wing, 2nd floor by room 2112 (lead/copper only)	ELB-50	0.34	<0.0010
12/17/2024	ELB, Tall DF by room 1055 (lead/copper only)	ELB-51	0.45	<0.0010
12/17/2024	ELB, Tall DF, South Wing, 2nd floor by elevator lobby (lead/copper only)	ELB-52	0.36	<0.0010
12/17/2024	ELB, SF in room 2394 (lead/copper only)	ELB-53	0.94	<0.0010
12/17/2024	ELB, Short DF, North Wing, 1st floor restrooms (lead/copper only)	ELB-54	0.31	<0.0010
12/17/2024	ELB, WBFS, South Wing. 3rd floor by elevator lobby (lead/copper only)	ELB-55	0.28	<0.0010
12/17/2024	ELB, SF by room 3047 (lead/copper only)	ELB-56	0.58	<0.0010
12/17/2024	ELB, Short DF by room 3061 (lead/copper only)	ELB-57	0.18	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

WBFS = Water Bottle Fill Station

Highlighted Orange = elevated above Action Level