

Date	Field House (FH), Location	Sample ID	Copper	Lead
10/10/2023	FH, DF, Room 123- Hockey Rooms 4-5-6 (lead/copper only)	FH-26	0.052	<0.0010
10/10/2023	FH, DF, Room 117- Hockey Rooms 1-2-3 (lead/copper only)	FH-27	0.13	<0.0010
10/10/2023	FH, DF adjacent to Room 119- Men's Locker Room, south end of gym (lead/copper only)	FH-28	0.043	<0.0010
10/10/2023	FH, SF in Room 216- Concession Stand (lead/copper only)	FH-29	0.16	<0.0010
12/17/2024	FH, DF by Conference room 209 (Lead/copper only)	FH-30	0.19	<0.0010
12/17/2024	FH, DF in room 117 (lead/copper only)	FH-31	0.07	<0.0010
12/17/2024	FH, DF adjacent to room 107, Women's Locker Room (lead/copper only)	FH-32	0.11	<0.0010
12/17/2024	FH, SF in room 216- Concession Stand (lead/copper only)	FH-33	0.18	<0.0010
	<b>Action Level (EPA/ MDEQ)</b>		<b>1.3</b>	<b>0.015</b>

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level