

Date	Grounds Building (GB), Location	Sample ID	Copper	Lead
10/3/2023	GB, SF in break room, 103 (lead/ copper only)	GB-13	0.12	<0.0010
10/3/2023	GB, DF by restrooms, 104/105 (lead/ copper only)	GB-14	0.0042	<0.0010
12/13/2024	GB, SF in break room, 103 (lead/ copper only)	GB-15	0.12	<0.0010
12/13/2024	GB, DF by restrooms, 104/105 (lead/ copper only)	GB-16	<0.0010	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level