

Date	Heinz Prechter Engineering Complex (HPEC), Location	Sample ID	Copper	Lead
10/12/2023	HPEC, short DF by room 1231 (lead/ copper only)	HPEC-26	0.18	<0.0010
10/12/2023	HPEC, tall DF by rooms 2070/2080 (lead/ copper only)	HPEC-27	0.29	<0.0010
10/12/2023	HPEC, SF in room 2180B (lead/copper only)	HPEC-28	0.44	<0.0010
12/13/2024	HPEC, tall DF by room 1231 (lead/ copper only)	HPEC-29	0.12	<0.0010
12/13/2024	HPEC, tall DF by room 2330 (lead/ copper only)	HPEC-30	0.13	<0.0010
12/13/2024	HPEC, SF in room 2180B (lead/copper only)	HPEC-31	0.35	<0.0010
	<b>Action Level (EPA/ MDEQ)</b>		<b>1.3</b>	<b>0.015</b>

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level