

Date	Natural Sciences Building- South (NSBS- f.k.a., Computing Wing) Building, Location	Sample ID	Copper	Lead
10/5/2023	NSBS, Short DF by rooms 1123/1125 (lead/copper only)	NSBS-21	0.41	<0.0010
10/5/2023	NSBS, DF by room 1112 (lead/copper only)	NSBS-22	0.25	<0.0010
10/5/2023	NSBS, DF by top of 2nd floor stairs (lead/copper only)	NSBS-23	0.33	<0.0010
12/12/2024	NSBS, tall DF by rooms 1123/1125 (lead/copper only)	NSBS-24	0.36	<0.0010
12/12/2024	NSBS, DF by room 1112 (lead/copper only)	NSBS-25	0.27	<0.0010
12/12/2024	NSBS, DF by top of 2nd floor stairs (lead/copper only)	NSBS-26	0.3	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

Highlighted Orange = elevated above Action Level