

Date	University Center (UC) Building, Location	Sample ID	Copper	Lead
10/12/2023	RUC, WBFS by rooms 1241/1243 (lead/copper only)	RUC-51	0.028	<0.0010
10/12/2023	RUC, right SF in room 1208 (lead/copper only)	RUC-52	0.093	<0.0010
10/12/2023	RUC, KSF adjacent to Picasso Restaurant Group kitchen office (lead/copper only)	RUC-53	0.075	<0.0010
10/12/2023	RUC, KSF adjacent to 3-sink dish wash area (lead/copper only)	RUC-54	0.095	<0.0010
10/12/2023	RUC, Tall DF by rooms 2185/ 2187 (lead/copper only)	RUC-55	0.054	<0.0010
10/12/2023	RUC, Short DF by rooms 2185/ 2187 (lead/copper only)	RUC-56	0.052	<0.0010
12/4/2024	RUC, WBFS by rooms 1241/1243 (lead/copper only)	RUC-57	0.042	<0.0010
12/4/2024	RUC, SF in room 1208 (lead/copper only)	RUC-58	0.1	<0.0010
12/4/2024	RUC, KSF adjacent to Picasso Restaurant Group kitchen office (lead/copper only)	RUC-59	0.068	<0.0010
12/4/2024	RUC, KSF adjacent to 3-sink dish wash area (lead/copper only)	RUC-60	0.042	<0.0010
12/4/2024	RUC, Tall DF by rooms 2185/ 2187 (lead/copper only)	RUC-61	0.046	<0.0010
12/4/2024	RUC, Short DF by rooms 2185/ 2187 (lead/copper only)	RUC-62	0.035	<0.0010
12/4/2024	RUC, DF by room 1127 (lead/copper only)	RUC-63	0.18	<0.0010
12/4/2024	RUC, SF in room 1123 (lead/copper only)	RUC-64	0.32	<0.0010
12/4/2024	RUC, SF in room 1145 (lead/copper only)	RUC-65	0.26	<0.0010
12/4/2024	RUC, SF in room 1133 (lead/copper only)	RUC-66	0.42	<0.0010
12/4/2024	RUC, SF in room 1183 (lead/copper only)	RUC-67	0.29	<0.0010
	<b>Action Level (EPA/ EGLE)</b>		<b>1.3</b>	<b>0.015</b>

SF = sink faucet

DF = drinking fountain

KSF = Kitchen Sink Faucet

WBFS = Water Bottle Fill Station

Highlighted Orange = elevated above Action Level