

Date	Science Faculty Center (SFC- f.k.a, Academic Support Center), Location	Sample ID	Copper (mg/L)	Lead (mg/L)
10/12/2023	SFC, SF in room 121 (lead/copper only)	SFC-52	0.40	<0.0010
10/12/2023	SFC, tall DF by room 1002 (lead/copper only)	SFC-53	0.19	<0.0010
10/12/2023	SFC, WBFS by room 2000A (lead/copper only)	SFC-54	0.29	<0.0010
12/12/2024	SFC, SF in room 121 (lead/copper only)	SFC-55	0.34	<0.0010
12/12/2024	SFC, ADA DF near room 1002 (lead/copper only)	SFC-56	0.17	<0.0010
12/12/2024	SFC, ADA DF near room 2000A (lead/copper only)	SFC-57	0.27	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

WBFS = Water Bottle Fill Station

Highlighted Orange = elevated above Action Level