

Date	Social Sciences Building (SSB), Location	Sample ID	Copper	Lead
10/12/2023	SSB, Tall DF by 1048E (lead/copper only)	SSB-49	0.14	<0.0010
10/12/2023	SSB, KSF inside room 1311 (north side)	SSB-50	0.81	<0.0010
10/12/2023	SSB, SF in 2142 (lead/ copper only)	SSB-51	0.37	<0.0010
10/12/2023	SSB, SF in room 2220 (lead/copper only)	SSB-52	1.4	<0.0010
12/17/2024	SSB, WBFS near 1048E (lead/copper only)	SSB-53	0.22	<0.0010
12/17/2024	SSB, KSF inside room 1311 (north side) (lead/copper only)	SSB-54	0.89	0.0062
12/17/2024	SSB, ADA DF by room 2144 (lead/copper only)	SSB-55	0.47	<0.0010
12/17/2024	SSB, KSF in room 2142 (lead/copper only)	SSB-56	0.55	<0.0010
	Action Level (EPA/ MDEQ)		1.3	0.015

SF = sink faucet

DF = drinking fountain

WBFS = Water Bottle Fill Station

KSF = Kitchen Sink Faucet

Highlighted Orange = elevated above Action Level