

Date	Wellness Center (WC) Building, Location	Sample ID	Copper	Lead
10/10/2023	WC, ADA DF by free weights (lead/copper only)	WC-29	0.29	<0.0010
10/10/2023	WC, SF in Training Room (lead/copper only)	WC-30	0.05	<0.0010
12/17/2024	WC, WBFS, by Womens restroom, 1st floor (lead/ copper only)	WC-31	0.085	<0.0010
12/17/2024	WC, Tall DF, lower level (lead/copper only)	WC-32	0.38	<0.0010
	<b>Action Level (EPA/ MDEQ)</b>		<b>1.3</b>	<b>0.015</b>

SF = sink faucet

DF = drinking fountain

WBFS = Water Bottle Fill Station

Highlighted Orange = elevated above Action Level